



Spare Parts List Aeration Tank and Blower

Rev 0
Date: 30/10/17

Minor Service Spare Parts

No spare parts are required for the Minor Service on the Ultraspin Aeration Tank and Blower unless components are damaged or need replacing.

Major Service Spare Parts

No spare parts are required for the Minor Service on the Ultraspin Aeration Tank and Blower unless components are damaged or need replacing.

Other Spare Parts

Customers may choose to purchase the following parts to:

- Upgrade the equipment to suit their application
- Hold onsite to ensure parts are readily available
- Replace items in the event they become damaged

| Description | Part No. |
|--|---------------|
| Ring Air Blower: nominally 100 m ³ /h @ 15 kPa, IP 55+, 1.5 kW motor, AL body | AER-BLOWER-02 |
| Aeration Hose Kit. 1"ID petrol & oil resistant discharge hose, 6mtr long, 1" BSP(m) & 2" BSP(m) ends | AER-HKT-01 |
| Aeration Hose Kit. 1/2" OD nylon air hose, 6mtr long, 1" BSP(m) & 3/4" BSP(m) ends | AER-HKT-02 |
| Aeration tank. 5kL heavy duty plastic tank, internal 1" sparger, 1/2" sample valve, tank fittings | AER-TANK-01 |
| Tank lid (with breather) and mounting ring, 620mm | TKF008 |
| Electric motor: 1.5 kW, 2P, 415 Vac/3 phase/50 Hz, IP55, flange mounted* | PMP223 |

* This is the Ultraspin standard motor. If a custom motor is preferred or required to meet site specifications, please contact Ultraspin with details on the motor required.